



1. ALL BACKFLOW PREVENTION DEVICES SHALL HAVE AN 18" MINIMUM CLEARANCE BETWEEN THE BOTTOM OF THE VALVE AND THE FLOOR TO PERMIT SUBMERSION AND PROVIDE ACCESS FOR SERVICING THE RELIEF VALVE.
2. 12" MINIMUM CLEARANCE SHALL BE MAINTAINED ABOVE THE ASSEMBLY TO ALLOW SERVICING CHECK VALVES AND FOR OPERATION OF SHUT-OFF VALVES.
3. AT LEAST 8 INCHES CLEARANCE SHOULD BE MAINTAINED FROM THE BACK OF THE DEVICE TO THE NEAREST WALL OR OBSTRUCTION.
4. THE MINIMUM CLEARANCE MAINTAINED BETWEEN THE BOTTOM OF RELIEF AND TOP OF CONCRETE SLAB.
5. CONTRACTOR SHALL VERIFY ALL DIMENSIONS PRIOR TO INSTALLING THE ASSEMBLY.
6. PLUMBING WORK SHALL BE 10 FEET AWAY FROM PRESSURE DEVICES SHALL BE DONE ON IRON PIPE, COPPER OR BRASS.
7. AIR GAP FITTINGS ARE NOT ALLOWED.
8. CONTRACTOR TO PURCHASE 2" BADGER METER FROM BLAIR SUPPLY.

NOT TO SCALE



DRAWING ALTERATION		REVISIONS	
Scale	NONE	Date	
Date	06/16/2016		
Job No.	201512		
Designed by	JMK		
Drawn by	JMK		
Checked by	JCA		
Approved by	JCA		

Client	FLOWERS BY STELLA
Project	FLOWERS BY STELLA RETAIL DEVELOPMENT
Drawing	BACKFLOW PREVENTION DETAILS
Sheet No.	BP-1
Drawing No.	

