

Comments for planning and ZBA boards 5/3/17

4690 North road CPN-025-17

1. Did this get submitted to Dave Degeer of Canandaigua Farmington water?
2. I will inspect the driveway culvert. If in poor condition we will change out.

3822 County road 16 CPN-031-17

1. A detail showing the minimum distance between the sanitary sewer and the water service of 18 inches from the bottom of the pipe to the top of the pipe.
2. A detail showing a minimum of 10 feet of separation of the sanitary sewer and water service.
3. Per town code a pressure reducing valve must be installed after the water meter.
4. Contractor will need to schedule a day and time 24 hours in advance to inspect the water service before back filling.

4905, 4907, 4911 County road 16 CPN-029-17

1. The town will need a written letter asking for the properties that are being combined to one property that the water meter is no longer present in the homes being torn down. This will remove them from being billed quarterly.
2. When directional drilling under county road 16 what is the depth of the forced sewer main? The town has an 8 inch PVC DR-14 water main 5 feet in the ground on the east side of the road. Before drilling I ask to be informed 24 hours in advance of the work to commence.
3. None of the drawings have shown any detail for the existing or future water service. Please provide the information.
4. Will the water services need to be all excavated and disconnected from the water main?
5. A reduced pressure water valve must be installed.
6. A Reduced pressure zone device (RPZ) must be installed inside the property of the home and have access to it for annual inspection. A licensed engineer will have to submit drawings and data to the town of Canandaigua and the Dept. of Health for approval.
7. Does the home require any high volumes of water?
- 8.