

zoninginspector@townofcanandaigua.org

From: Scott A. Harter, P.E. <proengineer1@prodigy.net>
Sent: Wednesday, September 5, 2018 5:37 PM
To: zoninginspector@townofcanandaigua.org
Subject: Re: 5747 Barnes Road - First Submittal

Eric:

Yes that is pretty much our sentiment on this one too.

The side slopes coming off of the house and barn are labelled such as 1V:3H meaning 1' vertical to 3' horizontal or 33%. 1V:4H also labelled is 25%. If we go steeper than 1V:3H, it becomes difficult to mow. If we go steeper than 1V:2H (50%) then we need jute mesh or soil stabilization. We show no proposed slopes steeper than 1V:3H.

So this the thought process for proposed slopes.

Please let us what we are to do next.

Thanks

Scott

Scott A. Harter, P.E.
Professional Engineering Group
7171 Victor-Pittsford Road
Victor, New York 14564
Phone: (585) 924-1860
Fax: Scan to email below
Email: Proengineer1@prodigy.net
Website: www.proengineeringgroup.com

On Wednesday, September 5, 2018 4:39 PM, "zoninginspector@townofcanandaigua.org" <zoninginspector@townofcanandaigua.org> wrote:

Scott,

Nothing really sticks out too much. Not in an area of particular environmental significance. Drainage and Soil Erosion will likely be the biggest concern. What is the slope of the land to be created surrounding the house? Looks fairly steep.

Little notes that might be missing will be addressed at the PRC meeting. But nothing really sticks out. Shouldn't be too bad.

Best,

Eric A. Cooper

Zoning Inspector
Town of Canandaigua
ecooper@townofcanandaigua.org
585-394-1120 x2254

From: Scott A. Harter, P.E. <proengineer1@prodigy.net>
Sent: Tuesday, August 28, 2018 8:50 AM
To: Eric Cooper <ecooper@townofcanandaigua.org>
Subject: 5747 Barnes Road - First Submittal

Eric:

Per your 7/23 comments, we made some adjustments to the site design and are going to submit our application today.

Let know what you think when it is received. I believe that I understand that you want one copy of everything at this time and so that is what we will provide.

Thanks

Scott

Scott A. Harter, P.E.
Professional Engineering Group
7171 Victor-Pittsford Road
Victor, New York 14564
Phone: (585) 924-1860
Fax: Scan to email below
Email: Proengineer1@prodigy.net
Website: www.proengineeringgroup.com

