



Comments for Center Point Apartments

Date 10/17/18

Application No: ^{CPN-18-066}CPN-18-006

- 1. All new 4" services should be DR14 PVC pipe.**
- 2. The existing water main should be Flushed and Chlorinated and health sampled. The line has been dormant for many years.**