

1. ALL MATERIAL AND WORKMANSHIP SHALL CONFORM WITH THE REQUIREMENTS OF THE LATEST REVISION OF THE INTERNATIONAL BUILDING CODE 2018 AND THE 2020 NEW YORK STATE-BASED DESIGN ACCORDANCE TO ASH 900C-88W/31-16, NORTH AMERICAN SPECIFICATION FOR THE DESIGN OF COLD-FORMED STEEL STRUCTURAL MEMBERS, AND WITH ANSI/AISC 7-16.
2. NO LOADS OTHER THAN THOSE GIVEN UNDER "DESIGN DATA" SHALL BE IMPOSED ON THE "STRUCTURE".
3. SPECIFIC NOTES AND DETAILS SHOWN ON THE DRAWINGS SHALL TAKE PRECEDENCE OVER THE BUILDING MANUAL SUPPLIED.

4. THE BUILDING, INCLUDING THE FOUNDATION, MUST BE CONSTRUCTED IN STRICT ACCORDANCE WITH THE DRAWING AND ERECTION INSTRUCTIONS. ANY DEVIATION, UNLESS APPROVED BY US IN WRITING, SHALL NULLIFY OUR CERTIFICATE AND SEAL AND SHALL BE THE SOLE RESPONSIBILITY OF THE ERECTOR.

5. A PROFESSIONAL ENGINEER SHOULD BE RETAINED WHERE SITE INSPECTIONS ARE WARRANTED.

6. NO ARCH PANEL MAY BE CUT OR MODIFIED UNLESS IT IS TO ACCOMMODATE AN ACCESSORY PROVIDED BY THE MANUFACTURER IN ACCORDANCE WITH ITS INSTRUCTIONS AND/OR THIS DRAWING.

7. MINIMUM SEPARATION FROM THIS BUILDING TO ANY TALLER BUILDING MUST BE THE SMALLER OF 20 FEET AND 6 TIMES THE HEIGHT DIFFERENCE.

8. IF SEALED BY AN ENGINEER, THIS DRAWING IS FOR PERMIT APPLICATION. OTHERWISE IT IS A DRAFT

NOTE: THE FOUNDATION ON THE DRAWING SPECIFIES THE MINIMUM REQUIREMENTS. LOCAL BUILDING CODE AND SITE CONDITIONS MAY REQUIRE A STRONGER FOUNDATION, WHICH MUST BE DESIGNED BY A LOCAL ENGINEER.

1. THE FOUNDATION SHALL BE FOUNDED ON NATURAL UNDISTURBED SOIL CAPABLE OF SAFELY SUSTAINING 1500 psf. THIS SHALL BE DESIGNED TO FULLY RESIST ALL ROTATION AT THE BASE OF THE ARCH.

2. SLAB ON GRADE SHALL BE PLACED ON WELL COMPACTED SOIL CAPABLE OF SUSTAINING 1500 psf WITHOUT APPRECIABLE SETTLEMENT.

DESIGN DATA (MATERIALS)

1. CONCRETE $f'_c = 2500$ PSI @ 28 DAYS, ACI
2. REINFORCING STEEL GRADE 40, $F_y = 40$ KSI, ASTM A615
3. W.W.R. $F_y = 65$ KSI, ASTM A504,
4. W.W.R. 6 x 6 - W14 x W14

ABCH DATA

ARCH DATA


 BOLTS: SAE GRADE 2 OR ASTM A307
 Arch A: 10 Arches
 ROOF STEEL THICKNESS = 0.03 in.
 Arch B: 10 Arches
 ROOF STEEL THICKNESS = 0.04 in.

GALVALUME SHEET STEEL
 STRUCTURAL QUALITY ASTM SPECIFICATION A792-10 (2015)
 55% ALUMINUM-ZINC ALLOY (HOT DIP COATING)
 ASTM A792 GRADE 50A
 50 KSI MINIMUM YIELD
 85 KSI MINIMUM TENSILE
 HSS SECTIONS SHALL CONFORM TO:

ASTM A500 GRADE B ($F_y = 46 \text{ ksi}$)
W SECTIONS SHALL CONFORM TO:
ASTM A992 GRADE 50 ($F_y = 50 \text{ ksi}$)
OTHER SECTIONS SHALL CONFORM TO:
ASTM A36 ($F_y = 36 \text{ ksi}$)
ARCH DESIGN DATA IN ACCORDANCE WITH AISC/ASCE 7-16:

Lc: ROOF LIVE LOAD (PSF) = 20
 Pgi: GROUND SNOW LOAD (PSF) = 40
 Ce: EXPOSURE FACTOR = 1.0
 Ct: THERMAL FACTOR = 1.0
 IMPORTANCE FACTOR (SNOW) = 0.8
 CATEGORY 1/AGRICULTURAL BUILDING
 Pref: COMPONENT WIND PRESSURE (PSF) = +/- 19


V : BASIC WIND SPEED (MPH) = 100
K_V: VELOCITY PRESSURE EXPOSURE = 0.85
G_{CP}: PRODUCT OF INTERNAL PRESSURE COEFFICIENT
AND GUST-EFFECT FACTOR = +/− 0.18
K_d: WIND DIRECTIONALITY FACTOR = 0.85
K_z: TOPOGRAPHIC FACTOR = 1.0

Ref: Ground Elevation Factor = 1.00
 WIND EXPOSURE CATEGORY = C
 SEISMIC DESIGN CATEGORY = B

LEGAL NOTE
This drawing is the property of Future Steel Buildings Int'l. Corp. Any duplication of this drawing in whole or in part is strictly forbidden. Anyone doing so will be prosecuted under the full extent of the law.

220 Chrysler Drive, Brampton, Ontario, Canada, L6S 6H8, Phone: (905) 790-8500	SteelMaster Buildings
DATE: 9/06/2022	APPROVED BY: J.A.
BY: ATU	DECODED BY:
K15	P. 010

PROJECT:	DAVID ZABOROWSKI CANANDAIGUA, NY	
MODEL:	Q30-15	81-62497 JWG






WARNING: DO NOT REMOVE OR REDUCE THE CONCRETE FLOOR OR THE REINFORCING STEEL, AND/OR RAISE THE TOPS OF THE FOOTERS ABOVE THE FLOOR OR BUILDING FAILURE MAY RESULT

Minimum Concrete Cover:

(a) Concrete Cast against earth:
(b) Concrete exposed to earth or weather:

(b) complete exposure to editorial review
No. 6 through No. 10 bars:
No. 5

(c) Concrete not exposed to earth



OR EQUIVALENT
1/4" x 1-3/4" x 1-3/4"
STEEL WASHER

ASTM F 436
OR EQUIVALENT

5 1/4"

CONCRETE EMBEDMENT

ANCHOR DETAIL

FOUNDATION PLAN

FOUNDATION PLAN
