



CITY OF CANANDAIGUA FIRE DEPARTMENT

Fire Chief Frank Magnera
335 South Main Street
Canandaigua, NY 14424-2118
Phone (585) 396-5052 Fax (585) 394-2706



Plan Review Comments

Application CPN-18-086
Ontario County IDA
2450 Brickyard Road, Canandaigua, NY

December 27, 2018

To whom this may concern:

Fire Department comments regarding the proposed Canandaigua Airport expansion.

- Please provide a new Fire Hydrants on airport property within 400' of the proposed buildings / hangers. The existing hydrant locations on Brickyard Road are not a practical water source to utilize to the proposed buildings and exceeds allowable distances.
- Please provide 26' width for fire department access roads in areas where the height of the proposed buildings may exceed 30'.
- Access roads must be an approved driving surface capable of supporting the imposed load of fire apparatus weighing at least 75,000 pounds.

I recommend a meeting to discuss placement of fire hydrants, fire department access roads and other concerns.

If you have any questions feel free to contact me. Thank you.

Respectfully,

Frank A. Magnera

Frank Magnera, MS, CFPS
Fire Chief & Fire Marshal