

Comments from the Highway Superintendent on the 1/8/19 planning board meeting

CPN-18-087 Robinson

1. Sent an email to Marks Engineering on the question of having to have a new water service installed for the property. Discussed how it would be less expensive to install a water service from the meter pit to the home. This will allow the property owners to place yard hydrants in location as it is past the water meter.
2. A pressure reducing valve must be installed inside the basement
3. If a new service is requested an application for it will need to be submitted and paid for before work can begin. There may be additional cost as crossing a state road will require an engineer drawing.

CBN-18-086 Brickyard road

- 
1. No comments

CPN-18-079 4803 County road 16

1. It appears that the water service is divided in two different services. One to the house and the other to the structure to the lake. If there is not a meter pit on County road 16 to the north of the driveway then the property owner will have to install one. The property has only one water meter on its account with the town. UPDATE went to property to determine if there is a water meter pit and none could be found. Property owner will have to install a water meter pit.
2. A pressure reducing valve will be required in both structures if water will continue to both of them.
3. When regarding the driveway care must be taken to keep a minimum of 48 inches of cover over the water service.