

**ecooper@townofcanandaigua.org**

---

**From:** Chris Jensen <cjensen@townofcanandaigua.org>  
**Sent:** Friday, October 23, 2020 8:22 AM  
**To:** michael.manikowski@co.ontario.ny.us  
**Cc:** devclerk@townofcanandaigua.org; ecooper@townofcanandaigua.org;  
lance.brabant@mrbgroup.com  
**Subject:** IDA - Airport Terminal

Good morning,

We received the plans for the proposed terminal and are writing up the Zoning law determination.. which will be sent out later today/Monday.

My only comment on the plan is the lack of information/design on the proposed on-site wastewater system. If you are unable to perform soils testing and provide design prior to Planning Board meeting, I will request that the site plan be conditionally approved and signatures not be placed on plans until receipt of septic design.

Thanks,  
Chris