

Comments for the planning board

Application # CPN-20-075

1. Water is provided by Canandaigua Farmington water district.
2. NO open cutting of the road will be allowed
3. Will need a permit for working in the right of way

Application # CPN-20-076

1. NO comments

Application # CPN-20-074

1. No Comments

Application # CPN-20-072

1. Drawing C-2 has conflicting notes on the water service. Under general and utility notes # 14 has the contractor and the town inspecting the $\frac{3}{4}$ inch copper water service that feeds the home to determine if it is suitable to use and another note to tap the water main and install a 1-inch service to a meter tile. What is a meter tile ? Then increases it to a 1.5-inch water service. Clarification is needed
2. IF a new water serve is required then the town will need permission to open cut County road 16. All expenses to open cut and pave the road will be the home owners cost along with the new water service.
3. Remove Canandaigua Farmington water and sewer from C-2 and replace with Canandaigua Consolidated water district.
4. Update the typical water service to our current site design. NO longer use a double strap bronze on PVC and copper pipe is not used anymore due to soil conditions are corrosive to the copper. All water materials are to be Mueller only no exceptions
5. Any irrigation will require a double check valve that will need approval from the NYS DOH and the town of Canandaigua water superintendent.
- 6.