

From: Havens, Donald E <Donald.Havens@ontariocountyny.gov>
Sent: Monday, December 7, 2020 9:51 AM
To: devclerk@townofcanandaigua.org
Subject: Application No. CPN-20-085

Good morning

Preliminary comments on the preliminary plans received on November 25th, 2020 follow as"

- Pretreatment units will be required if the hanger bay has a floor drainage system.
- There is a current 6" stub to service this property at station 11+ 65, unless they choose to connect downstream as shown.
- If connecting downstream is the preferred option it will require a cut in 8"X6" Wye.
- Lateral size needs to be changed to 6" SDR 21.
- Cleanouts at every change of direction and every 90'.

A more thorough review will be performed once more detailed drawings are provided.

Thanks,

Don

Don Havens
Canandaigua Lake County Sewer District Supervisor
Ontario County Public Works Department
2962 County Road # 48
Canandaigua, N.Y. 14424-9553
Office (585) 396-4301
Office Hours: M-F 7:00 AM to 3:30 PM

"This message may contain confidential, sensitive and/or proprietary information and is intended for the person/entity to whom it was originally addressed. Any use by others is strictly prohibited."