

Comments for the Planning board for the 4/23/19 meeting

Application # CPN 19-019 Didsbury residents

1. Property owner or project manager work on behalf of owner will need to submit an application for new water service. The application is found online at the town's web site. Before the town will tap for a new service the application must be paid for first.
2. A pressure reducing valve must be installed after the water meter. Per town code.
3. IF applicant is installing an irrigation system it must have an approved back flow device approved by the town of Canandaigua and the NYS dept. of Health before installing.
4. Water and gas service need to be separated by 5 feet.
5. On note 15 per town site design the driveway must be paved to the right of way. This should be added to the plan
6. Contractor must verify depth of watermain before excavation begins to insure proper cover over water main. If less than four feet of cover is proposed the town water superintendent will not allow this to proceed.
7. Page C 500 note 2 remove town engineer as this will be determined by Ontario County highway engineer as this is a county road.

Application # CPN 19-012 Cdga country club

1. Due to the inaccuracy of the water main plans the town has on file the water superintendent will be engaging with a company to locate water main that is somewhere in the parking lot that is to be rebuilt. This will occur in the month of April. Contractor and the town will work together to locate when excavation begins.

Application # CPN 19-020

1. No comments

Application # CPN 19-014 Krenzer property

1. No Comments.
- 2.