

ahirschmann@townofcanandaigua.org

From: cjensen@townofcanandaigua.org
Sent: Wednesday, March 23, 2022 12:47 PM
To: ahirschmann@townofcanandaigua.org; 'Shawna Bonshak'
Subject: RE: Town of Canandaigua Referrals

Comments:

CPN 2022-014

- No comments

CPN 2022-015

- No Comments

CPN 2022-016

- Although Town Code does not require building numbers on a building sign, please provide building numbers on the building which can be legibly seen from Route 332.
- Planning Board should be made aware structure is an unconditioned seasonal produce market. Per Energy Code - structure is not to be utilized between September 15th and May 15th.

CPN 2022-017

- No comments

CPN 2022-018

- Recommend placing some type of barrier (decorative.. split rail.. or something similar) to prevent parking of vehicles on on-site wastewater field.

CPN 2022-019

- No comments

CPN 2022-021

- Applicant should be made aware of the near future revisions to the FEMA Flood Insurance Maps. If they are adopted prior to issuance of a building permit, the project may be referred back to Planning Board.

From: ahirschmann@townofcanandaigua.org <ahirschmann@townofcanandaigua.org>
Sent: Tuesday, March 22, 2022 1:58 PM
To: 'Chris Jensen' <cjensen@townofcanandaigua.org>
Cc: 'Shawna Bonshak' <sbonshak@townofcanandaigua.org>
Subject: Town of Canandaigua Referrals

Allison Hirschmann
Town of Canandaigua
Development Office Clerk