

Comments for the ZBA and Planning board in march of 2020

Application # CPN-20-011

BYT Holdings

1. On drawing C 100 a comment is on the plan stating a 1-inch service for irrigation. Before the water service is connected into the building a detail of the utility room in building # 1 should be presented to the water superintendent for review.
2. Any irrigation system must be engineered and submitted to the town of Canandaigua and the NYS DOH for approval before operation of the system can begin. This can take up to 8 months to get approval.

Application # CPN-20-006

4526 County road 16 Schutt residence

1. Need an explanation on why a 1.5-inch water service is needed. A one-inch water service will be sufficient.
2. Add to the plans distance from north end of septic field to water service a minimum of 10 feet.
3. Contractor or property owner will need to fill out the information for a new water service and pay the fee to tap water main.
4. A pressure reducing valve must be installed after the water meter.

Application # CPN-20-004

BME associates representing Casciano resident

1. A pressure reducing valve must be installed after the water meter
2. Contractor or property owner will need to fill out the information for a new water service and pay the fee to tap water main.
3. Any plans to install an irrigation system? If so property owner to contact the town of Canandaigua water department.

Application # CPN-20-008

Venezia representing Gerber homes

1. A pressure reducing valve must be installed after the water meter
2. Contractor or property owner will need to fill out the information for a new water service and pay the fee to tap water main.
3. Any plans to install an irrigation system? If so property owner to contact the town of Canandaigua water department.
- 4.