



# CITY OF CANANDAIGUA FIRE DEPARTMENT

**Fire Chief Frank Magnera**  
335 South Main Street  
Canandaigua, NY 14424-2118  
Phone (585) 396-5052 Fax (585) 394-2706



---

## Plan Review Comments

Application CPN-20-016 & CPN-20-017

Creekview Apartments & Clubhouse  
Woodland Park, Canandaigua, NY 14424

April 06, 2020

To whom this may concern:

The Fire Department has reviewed the proposed Site Plan regarding Phase 2 of the Creekview Apartments project.

- Will the water/fire mains eventually be looped or will they remain dead-end?
- Please provide FD with drawings of proposed solar panels locations on rooftops and disconnect locations for each building.
- Please provide clear, discernable signage for addresses / numbers on each building and apartment locations.
- Please provide additional Knox Boxes for building access and work with FD on locations and quantity.
- No comment on the Clubhouse expansion project.

No further comments.

If you have any questions, feel free to contact me. Thank you.

Respectfully,

*Frank A. Magnera*

Frank Magnera, MS, CFPS  
Fire Chief & Fire Marshal