

## Comments for Planning board

### Venezia for home on Lake Breeze Way

1. A pressure reducing valve will be required after the water meter.
2. Water application will need to be submitted to the town for a water meter.

### DiMarco Group Application # CPN-20-017

1. The town of Canandaigua will require a 20-foot easement over the water main.
2. A valve to each building that supplies water will need to be in this easement.
3. Connect the south branch of the water main back to phase 1 near bldg. 14. This will provide a looped water main for quality of water and fire protection.
4. All materials dedicated to the town must be submitted to the water superintendent for approval. Contactor needs to review our site design and development requirements.
5. A site inspector will be on site when water main and appendages are being installed.
6. Only an employee of the town of Canandaigua will operate the water system.
7. A detail of the backflow device in each building is needed.
8. Change the note to HDPE water service under road to bldg. 23.