



Ontario County Public Works

William C. Wright, P.E.
Commissioner of
Public Works
Office: (585) 396-4000

2962 County Road 48
Canandaigua, New York 14424-9553
www.co.ontario.ny.us
email: dpw@co.ontario.ny.us

John E. Berry, P.E.
Deputy Commissioner
of Public Works
Facsimile: (585) 396-4283


HIGHWAYS ~ ENGINEERING ~ WASTEWATER SYSTEMS & SEWERS ~ BUILDINGS & GROUNDS ~ PARKS ~ PUBLIC WORKS FINANCE

May 3, 2017

Brennan Marks
Marks Engineering
42 Beeman Street
Canandaigua, New York 14424

Re: 3822 County Road # 16

Dear Mr. Marks:



We are in receipt of a site plan set for the referenced project dated April 20, 2017.

The following is a list of action items that need to be addressed and satisfied before a permit will be issued by the Canandaigua Lake County Sewer District at the above referenced property:

GENERAL

1. Renovation permit required for connection.

SITE PLAN

1. If reusing current lateral the district requires that the lateral be televised to see that it is viable for reuse.
2. Add "Standard Sanitary Lateral Plan Notes".
3. Add District clean out detail.
4. Add lateral trench and bedding detail.
5. Add Sanitary Sewer Lateral Detail.
6. If current lateral is SDR-35 and is acceptable for reuse the same material can be reused if not the lateral will need to be brought up to District standard of SDR 21.
7. Clean outs are required every 90 feet and need to be labeled on the drawing.
8. The District recommends a clean out within 3 feet of the foundation but seeing that there will be a deck over the lateral in this location we would recommend it be placed in a convenient location to facilitate easy cleaning if necessary.
9. We require a minimum 18 inch vertical separation between the potable water and sanitary sewer. Add a description for this requirement. Alternatively realign water line to provide a 10 foot horizontal separation to the sewer lateral.

Please make revisions and resubmit to our office. If you have any questions I may be reached at (585) 396-4301

Sincerely,

Donald E. Havens, Jr.
Supervisor, Canandaigua Lake Sewer District

Enc.

cc: John E. Berry, P.E., Deputy Commissioner of Public Works (w/o enc.)
Chris Jensen, P.E., Code Enforcement/Zoning officer, Town of Canandaigua (w/o enc.)