

**From:** Havens, Donald E <Donald.Havens@ontariocountyny.gov>  
**Sent:** Tuesday, November 3, 2020 2:23 PM  
**To:** devclerk@townofcanandaigua.org  
**Subject:** November Zoning and Planning comments

Hi Michelle,

The Canandaigua Lake Sewer District has the following comments on the following applications.

- Application# - CPN-20-073 – Addition may impact sanitary lateral that services this address. Full site plan showing sewer lateral required for our review and may require a renovation permit from the District.
- Application# - CPN-20-076 – No Comments at this point.
- Application# - CPN-20-072 – Permit required for connection. Current drawings look in order but changes will require drawings to be resubmitted to this office. Also may require a County Highway ROW work permit.

Thanks,  
Don

**Don Havens**  
**Canandaigua Lake County Sewer District Supervisor**  
**Ontario County Public Works Department**  
**2962 County Road # 48**  
**Canandaigua, N.Y. 14424-9553**  
**Office (585) 396-4301**  
**Office Hours: M-F 7:00 AM to 3:30 PM**

"This message may contain confidential, sensitive and/or proprietary information and is intended for the person/entity to whom it was originally addressed. Any use by others is strictly prohibited."