

Report of Highway and Water superintendent for the ZBA

Application # CPN-19-003 DAGR

1. Concept looks favorable

Application # CPN-19-005 Blazak

1. Does the applicant plan on using an irrigation system? If so, the applicant must apply for a back-flow device to be approved by the Dept of Health and the town of Canandaigua.
2. The applicant will be required to install a new water meter in the house before Certificate of Occupancy is issued. There is no charge for this.
3. Applicant should review with their architect the amount of water needed to operate all water fixtures correctly. A ¾ inch water service may not be large enough for volume.
4. A pressure reducing valve must be installed after the water meter.