

devclerk@townofcanandaigua.org

From: Ohle, Tyler <Tyler.Ohle@ontswcd.com>
Sent: Monday, July 6, 2020 12:24 PM
To: devclerk@townofcanandaigua.org
Cc: 'Cooper, Eric'
Subject: RE: Town of Canandaigua June Referrals

To whom it may concern,

I offer the following comments:

In regards to Application # CPN-20-043, Tax ID: 139.00-1-12.111:

0000 Smith Rd

This office has not received an application or plans from the engineer for this proposed residence. After review of the plans provided by the town, It appears that the proposed wastewater system can support the proposed residence with minor revisions. This office must receive an application and 4 hard copies for official review and comments prior to any approval.

In regards to Application # CPN-20-038, Tax ID: 140.11-1-10.000:

4645 CO Rd 16

The existing septic system was designed and installed in 2017. The System was designed for a maximum of 600 Gallons per day to serve a 4 bedroom residence (2251-3300 square feet). This office request architectural plans to verify that the existing system meets the minimum standards for new construction for the proposed residence. This office cautions the town in granting approvals before it has been demonstrated that the existing onsite-wastewater system can support the proposed residence given the limited space.

In regards to Application # CPN-20-030, Tax ID: 140.11-1-14.000:

4641 N Menteth

This office has yet to receive plans for an onsite wastewater system for this proposed residence. This office cautions the town in granting any approvals before it has been demonstrated that the site can support an onsite system that serves the proposed residence.

Best,

Tyler Ohle, NYSESCCP
Canandaigua Lake Watershed Inspector
Ontario County Soil and Water Conservation District
Office: 585-396-9716 / Cell: 585-704-5819

From: devclerk@townofcanandaigua.org [mailto:devclerk@townofcanandaigua.org]
Sent: Monday, June 22, 2020 11:37 AM
To: Ohle, Tyler