

Comments for the planning and zoning board Oct 26, 2021.

App # CPN-21-073 Futerman

1. What is the purpose of two 1.5-inch water services?
2. Is the developer asking to tap the water main twice with a 1.5-inch saddle? Nothing it spelled out all I see is new service for 4799
3. It appears that they may use the existing curb stop for one of the water services. Is this correct?
4. Is the developer asking to have two water meters that are 1.5 inch?
5. Water meter must be accessible to the town of Canandaigua water department. No crawl spaces or stuck in a utility room that is not sized correctly for the water meter.
6. A pressure reducing valve will be required for each service line
7. If an irrigation system is installed a back flow device will need to be engineered and approved by the NYS DOH and the town of Canandaigua.
8. There are no details on sheet four in regards to the water service specifications found in our town site development.
9. The sanitary sewer and public water are crossing over each other. Show the elevation between the sewer and water. A minimum of 18 inch of separation is required.
10. On sheet 2 one note spells out 1.5-inch water service and another note say 1 inch water service. Which is it?
11. The one water service going to the house closest to the lake appears to be connecting to the new water service to the old water service. Are they both 1.5 inch and if not why run 1.5-inch water service to it?

App # CPN-21-050

1. No Comments.