

Town of Canandaigua

5440 Route 5 & 20 West
Canandaigua, NY 14424
(585) 394-3300
FAX (585) 394-3767

Established 1789

July 6, 2016

Comments for the planning board on upcoming projects

1. CPN-047-16 Sands Residence.
 - a. At this time the current meter pit is buried under fill and needs to be cleared of the dirt for access by the town to read the meter.
 - b. I understand that there may be a request to increase the size of the water service to the property. If this is true the current meter pit is undersized and will need to be replaced or have the water meter installed in the property.
 - c. A pressure reducing valve is required in all properties in the town of Canandaigua.
 - d. As noted on the plan if an auto fill valve is used for filling the pool a backflow devise is required and must be approved by the Dept. of Health and the town of Canandaigua. This devise must be annually inspected and a report submitted to the town.
- 2 CPN-046-16 Lewis Norry residence
 1. I have no comments.
- 3 CPN-041-16 City of Canandaigua
 1. No comments

Jim Fletcher