

**From:** [Havens, Donald E \(Donald.Havens@ontariocountyny.gov\)](mailto:Havens, Donald E (Donald.Havens@ontariocountyny.gov))  
**To:** [devclerk@townofcanandaigua.org](mailto:devclerk@townofcanandaigua.org)  
**Cc:** [May, Steven P](#)  
**Subject:** Application # CPN-21-036  
**Date:** Tuesday, May 11, 2021 8:40:41 AM

---

Hi Michelle,

The Canandaigua Lake Sewer District offers the following comments for application # CPN-21-036.

- Permit required for additional connection.
- More details required for connection up near existing AC lateral that services the club house.
- Provide lift station specifications.
- SDR 21 is the required lateral material for the gravity connection from the building to the lift station.
- Provide a more detailed drawing to the district for additional comments.

Thanks,  
Don

**Don Havens**  
**Canandaigua Lake County Sewer District Supervisor**  
**Ontario County Public Works Department**  
**2962 County Road # 48**  
**Canandaigua, N.Y. 14424-9553**  
**Office (585) 396-4301**  
**Office Hours: M-F 7:00 AM to 3:30 PM**



“This message may contain confidential, sensitive and/or proprietary information and is intended for the person/entity to whom it was originally addressed. Any use by others is strictly prohibited.”