

July 21, 2017

Comments on projects

App. # CPN-044-17

1. Property owner will need to submit to the town a paid application for water service.
2. Property owner to follow the standards of water service materials per the town of Canandaigua specification.
3. A pressure reducing valve is mandatory after the water meter and maintained by the property owner.
4. Mailbox should be 16 feet from the center of the road and a minimum height of 46 inches from the bottom of the box.

App # CPN-050-17

1. Water service is maintained by the Canandaigua Farmington Water District. Change on the plans to say so.

App # CPN-048-17

1. Awaiting the outcome of an upcoming meeting.

Jim Fletcher