

**From:** [Ohle, Tyler \(Tyler.Ohle@ontswcd.com\)](mailto:Tyler.Ohle@ontswcd.com)  
**To:** [mrowlinson@townofcanandaigua.org](mailto:mrowlinson@townofcanandaigua.org)  
**Cc:** "Chris Jensen"; "Shawna Bonshak"  
**Subject:** RE: Town of Canandaigua Referral-- May cont.  
**Date:** Wednesday, June 2, 2021 1:55:08 PM

---

In regards to 3556 Hickox Rd, Application No: CPN-2-049, Tax Map No: 97.00-1-52.120.

This office has not received a set of wastewater plans from the engineer. According to the site plan, the wastewater system is a raised fill system and will require approval from New York State Department of Health in Geneva prior to the construction of the wastewater system.

Best,

Tyler Ohle, NYSECCP  
Canandaigua Lake Watershed Inspector  
Ontario County Soil and Water Conservation District  
Office: 585-396-9716 / Cell: 585-704-5819

---

**From:** [mrowlinson@townofcanandaigua.org](mailto:mrowlinson@townofcanandaigua.org) [mailto:[mrowlinson@townofcanandaigua.org](mailto:mrowlinson@townofcanandaigua.org)]  
**Sent:** Tuesday, May 25, 2021 10:35 AM  
**To:** Ohle, Tyler  
**Cc:** 'Chris Jensen'; 'Shawna Bonshak'  
**Subject:** Town of Canandaigua Referral-- May cont.

**CAUTION:** This message originated outside the Ontario County email system. Do not click links or open attachments unless you recognize the sender and know the content is safe.

*Michelle Rowlinson*

Senior Clerk  
Town of Canandaigua  
585-394-1120 x2230  
[mrowlinson@townofcanandaigua.org](mailto:mrowlinson@townofcanandaigua.org)

“This message may contain confidential, sensitive and/or proprietary information and is intended for the person/entity to whom it was originally addressed. Any use by others is strictly prohibited.”