

Comments for Planning and Zoning board May 21 and May 28

Application # CPN-19-027 4609 Misty Hill Drive

1. The town will open cut the trench for the 1-inch water service
2. Property owner or a representative will need to submit a water application form with payment before work can begin for the water service. See the towns web site for application.
3. A pressure reducing valve is required after the water meter.
4. Inspection of water service must be witness by the town before backfilling

Application # CPN-19-024 Bero Contracting

1. No comments

* Application # CPN-19-029 4959 Island beach Drive

1. The water meter must be removed prior to demolition of house. Contractor to contact town to remove it.
2. Water curb stop will be turned off by the town and needs to be protected during construction
3. Does the home have plans to install an irrigation system? If so, a double check valve must be approved before installing.
4. A water services require a pressure reducing valve.
5. Will water service need to be relocated?

Application # CPN-10-030 Goal Investments

1. Will reserve comment at this time as further information is needed.

