

Comments for the Planning and Zoning boards 8/2020

4487 Middle Cheshire road

1. I recommend a minimum of a 1.5-inch water service from the water meter pit to the house.
2. Before the town taps the water main it needs to be paid to the town clerk's office.
3. Before backfilling for the trench for the water service the town will need to inspect. Call 394-3300 24 hours in advance to schedule.
4. Will the pool have an auto feed system to fill the pool when needed? Is it does a backflow devise will need to be submitted by an engineer to be approved by the town of Canandaigua and the NYS dept. of Health.
5. Need a pressure reducing valve inside the house.

5955 Knapp Road

1. NO Comments

5160 Parrish Street Ext.

1. NO Comments