

Eric Cooper

From: devclerk@townofcanandaigua.org
Sent: Wednesday, September 9, 2020 3:50 PM
To: 'Eric Cooper'
Subject: FW: CPN-20-58

-----Original Message-----

From: Braun, Jack D <Jack.Braun@co.ontario.ny.us>
Sent: Tuesday, September 8, 2020 3:50 PM
To: devclerk@townofcanandaigua.org
Subject: CPN-20-58

Good afternoon -

Our initial comment on the above-referenced application:

* Provide documentation confirming that the City of Canandaigua has signed off on the proposed sanitary sewer alignment that encroaches their water main easement and crosses their 30" transmission main.

A formal review of the application will take place upon receipt of the requested documentation as well information showing the burial depth of the City's 30" transmission main.

-jack

John D. Braun
Junior Engineer, CLCSD

Ontario County Department of Public Works
2962 County Road 48
Canandaigua, New York 14424
(585) 396-4049

"This message may contain confidential, sensitive and/or proprietary information and is intended for the person/entity to whom it was originally addressed. Any use by others is strictly prohibited."