

Eric Cooper

From: jfletcher@townofcanandaigua.org
Sent: Tuesday, February 18, 2020 11:01 AM
To: 'Scott A. Harter, P.E.'
Cc: 'Lance Brabant'; 'Eric Cooper'; 'Rocco Venezia'
Subject: RE: Fox Ridge - Phase 5B-1 Plans

Put a comment on the plan with an arrow pointing to the hydrant

From: Scott A. Harter, P.E. <proengineer1@prodigy.net>
Sent: Tuesday, February 18, 2020 7:55 AM
To: jfletcher@townofcanandaigua.org
Cc: 'Lance Brabant' <lance.brabant@mrbgroup.com>; 'Eric Cooper' <ecooper@townofcanandaigua.org>; 'Rocco Venezia' <rocco@veneziasurvey.com>
Subject: Re: Fox Ridge - Phase 5B-1 Plans

Jim:

Do you mean a note in the revision block stating "hydrant added"?

Scott

On Tuesday, February 18, 2020, 07:17:47 AM EST, <jfletcher@townofcanandaigua.org> wrote:

Scott

A note on sheet 3 under site and utility plan showing fire hydrant should be placed on it. Then you can submit back to me for DOH.

James Fletcher

Town of Canandaigua

Highway and Water Superintendent

585-394-3300

From: Scott A. Harter, P.E. <proengineer1@prodigy.net>

Sent: Friday, February 14, 2020 2:23 PM

To: Jim Fletcher <jfletcher@townofcanandaigua.org>

Cc: Lance Brabant <lance.brabant@mrbgroupp.com>; Eric Cooper <ecooper@townofcanandaigua.org>; Rocco Venezia <rocco@veneziasurvey.com>

Subject: Fox Ridge - Phase 5B-1 Plans

Jim:

Here are the updated plans that now include a hydrant at the end of the watermain.

Please advise/confirm that you are OK with these plans

If so, I will forward the DOH form for your signature.

Thank you,

Scott

Scott A. Harter, P.E.

Professional Engineering Group

7171 Victor-Pittsford Road

Victor, New York 14564

Phone: (585) 924-1860

Fax: Scan to email below

Email: Proengineer1@prodigy.net

Website: www.proengineeringgroup.com

