

Comments for Planning and Zoning Boards

3549 Lakewood Lane Application # CPN-20-003

1. Existing water meter needs to be removed and stored in a safe location. If water meter is lost or damaged property owner will be required to purchase new one.
2. If the applicant will be installing irrigation for the lawn an engineered design back flow device will need to be submitted to the town of Canandaigua and the NYS dept. of Health for approval.
3. A pressure reducing valve for the water service must be installed per town code.
4. Inspection of the water service must be performed before backfilling.

3060 County Road 10 Keith Rosato

1. No comments.