

CPN 2022-087 - CPN 2022-088

Alvermann – Lakeview Drive

- Provide existing conditions – site plan – demo plan. Showing the existing building on proposed plan makes it difficult to read. Difficult to see what is proposed and what is removed. Please remove overlay from proposed site plan.
- Proposed porch is within 5ft. of parcel boundary – Fire Separation distance – If approved architect should be made aware of requirements.
- Provide some elevation/information on the retaining walls. Label top of walls?