

## Zoning Inspector

---

**From:** Chris Jensen <cjensen@townofcanandaigua.org>  
**Sent:** Tuesday, April 24, 2018 3:48 PM  
**To:** "Eric Cooper"  
**Subject:** FW: 5265 Menteth Drive - Application CPN-18-018

For the file

---

**From:** Barden, George V [mailto:George.Barden@ontswcd.com]  
**Sent:** Tuesday, April 24, 2018 3:38 PM  
**To:** devclerk@townofcanandaigua.org  
**Cc:** Chris Jensen (cjensen@townofcanandaigua.org); Town Manager (dfinch@townofcanandaigua.org)  
**Subject:** 5265 Menteth Drive - Application CPN-18-018

All,

I apologize to you all for missing the April 17<sup>th</sup> deadline for comments on this application. But I have been very busy!----

I only have 2 comments since this proposal is to connect to the existing absorption system, and relocate the existing aerobic treatment unit and pump tank. With regards to this, DWG. # CA120 (sheet 5 of 8) the relocated pump tank is incorrectly labeled as "Relocated septic tank". There is no septic tank with this aerobic system.

My only other comment, is that this office will need the final architectural floor plans and plumbing plan to verify the number of bedrooms, and the types of water using appliances being proposed to ensure that what is being built does not overload this existing system hydraulically.

Again, I apologize for being late.

Respectfully submitted,

George V. Barden, CPESC  
Canandaigua Lake Watershed Inspector

"This message may contain confidential, sensitive and/or proprietary information and is intended for the person/entity to whom it was originally addressed. Any use by others is strictly prohibited."