

## Development Clerk

---

**From:** Ohle, Tyler <Tyler.Ohle@ontswcd.com>  
**Sent:** Tuesday, August 27, 2019 9:45 AM  
**To:** cjensen@townofcanandaigua.org; devclerk@townofcanandaigua.org  
**Subject:** Application No. CPN-19-066

Chris,

This office has received a set of plans and a request for comments from your office. Since this parcel falls within the Canandaigua Lake Watershed, this office will need to review the plans for the onsite wastewater treatment (septic) system. The appropriate Application Form and review fee must be submitted along with the plans. Approval of the system from this office should be obtained prior to issuance of the building permit. After quick review of pertinent data, I offer the following comments:

1. Soil data has seasonal high ground water @ 27", and roots to 12". The soil perc data does not show the depth of the test, with rates @ 13min. A 24" depth for a perc test must be shown to consider the proposed shallow trench system.

Should you or any other interested party have any questions regarding this matter, please feel free to contact this office at any time.

Tyler Ohle  
Canandaigua Lake Watershed Inspector  
Ontario County Soil and Water Conservation District  
Office: 585-396-9716 / Cell: 585-704-5819  
[Canandaigua Lake Watershed Inspection Program](#)

"This message may contain confidential, sensitive and/or proprietary information and is intended for the person/entity to whom it was originally addressed. Any use by others is strictly prohibited."