

Jim Fletcher's Comments for 8/16/2016 planning board

3999 Middle Cheshire road Marathon Engineering for Morrell Builders.

1. On page CO.1 under utilities all water main materials are to be Mueller and all cast iron fittings are to be Tyler.
2. Fire Hydrants are to be red.
3. All gate valves are to be Mueller.
4. Before any water main materials are installed the water superintendent will be called to inspect materials for correct manufacture.
5. Tracer wire is to be placed with the water main and looped at the fire hydrants.
6. When will the 8 inch water main be connected to the water main on Charing Cross? This should be done in this phase for fire protection.
7. I did not see any detail for intersection lights at the intersections. Will this be installed?
8. Once the new road is installed for section 9B I will require all contractors, trucks, employees, to use this entrance only.
9. Any trees to be planted will need to be approved with the water and highway superintendent for the town of Canandaigua and the Ontario County Lake county sewer.
10. All utility crossing are to be filled with crusher run and compacted.