

3614 Middle Cheshire Rd

Comments from the highway and water superintendent

August 27, 2018

Application # CPN-18-057

1. The site work for the driveway and retaining wall should have the contractor verify that there will be at least 42 inches of cover over the water service to prevent from freezing.

Application # CPN-18-059

1. The applicant will be required to purchase a one inch meter pit, one inch meter, and materials for tapping the water main. The fee for this is \$ 1,655.00.
2. A two inch water service should be ran after the meter pit with a 10 gauge solid copper tracer wire and sand bedding.
3. A reduce pressure valve is required in all homes in the town of Canandaigua. This device is maintained by the property owner.
4. If the water service is not one continuous pipe a marker locating the connection should be placed.
5. Trench must be inspected by the town water department before backfilling.

Application # CPN-18-055

1. No comments