

Development Clerk

From: Gerace, Tad W <Tad.Gerace@ontswcd.com>
Sent: Tuesday, April 25, 2017 3:34 PM
To: devclerk@townofcanandaigua.org
Subject: 4690 north road 57-1-24.140 review

i received a copy of the site plan for the above address in the us mail today and completed a review for the town of canandaigua at no fee. however, all alternative systems should be reviewed by the nys department of health for approval.

my comments are as follows:

- 1- the 50% expansion area is, although workable, located in a somewhat awkward area and the nys doh design handbook states whenever possible a 100% expansion/replacement area be provided.
- 2- if existing field tiles are discovered in or around the leach area it is recommended they be cut off and not routed to the road ditch as stated.
- 3- according to the nys doh design handbook, garbage grinders should not be installed. however, if they are utilized, an effluent filter must be provided.
- 4- the use of a flout is interesting. how did the 63 gallon drawdown get determined? is that 63 gallons per dose?
- 5- the nys doh recommends 1000-gallon septic tanks for a 3-bedroom house be pumped every 3-5 years for proper maintenance.

thanks.

tad

tad gerace
conservation district technician
585-396-1450

“This message may contain confidential, sensitive and/or proprietary information and is intended for the person/entity to whom it was originally addressed. Any use by others is strictly prohibited.”