



# Ontario County Public Works

William C. Wright, P.E.  
Commissioner of  
Public Works  
Office: (585) 396-4000

2962 County Road 48  
Canandaigua, New York 14424-9553  
www.co.ontario.ny.us  
email: dpw@co.ontario.ny.us

John E. Berry, P.E.  
Deputy Commissioner  
of Public Works  
Facsimile: (585) 396-4283

HIGHWAYS ~ ENGINEERING ~ WASTEWATER SYSTEMS & SEWERS ~ BUILDINGS & GROUNDS ~ PARKS ~ PUBLIC WORKS FINANCE

November 17, 2017

Justin Kellogg, P.E.  
Meagher Engineering  
PO Box 76  
Victor, New York 14564

Re: Mr. & Mrs. Patronski  
4069 Onnalinda Drive, Lot 2  
Canandaigua, New York 14424

Dear Mr. Kellogg:

We are in receipt of a site plan set for the referenced project dated November 8<sup>th</sup>, 2017.

## GENERAL

1. Permit required for connection

## SITE PLAN

1. Current gravity connection design will not be permitted due to the future abandonment of the section of sanitary sewer in the future.
2. Design and detail sewage lift station and force main. "E-One" models were recommended and approved for use on the other two parcels to the south of this parcel
3. Add sewer lateral connection to the gravity sewer main to the west for the lift station force main.
4. Label 8" SDR 35 Main and manholes (record drawing provided).
5. Force main shall be connected via a 4" Inserta Tee" or
6. Connection shall be 2 repair couplings and a 8" X 4" SDR 35 wye. Couplings shall be a minimum of 2 feet from an existing joint. Stubs from wye to coupling shall be a maximum of 2 feet in length.(see detail)  
In either case label distance along the main from the center of manhole to new connection.

## SITE AND UTILITY DETAILS

1. Remove and replace your standard details with our standard details.
2. Add wastewater force main detail.
3. Add trenching and bedding detail.
4. Add lateral detail.
5. Add cleanout detail.
6. Add lateral riser detail.
7. Add "Inserta Tee" detail.
8. Add cut in wye detail.
9. Add "Sanitary Lateral Notes".
10. Provide a plan showing how groundwater collected and conveyed by the force main trench constructed on a hillside is to be properly managed.

Please make revisions and resubmit to our office. If you have any questions I may be reached at (585) 396-4301

Sincerely,

Donald E. Havens, Jr.  
Supervisor, Canandaigua Lake Sewer District

Enc.

cc: John E. Berry, P.E., Deputy Commissioner of Public Works (w/o enc.)  
Chris Jensen, P.E., Code Enforcement/Zoning officer, Town of Canandaigua (w/o enc.)