

Zoning Inspector

From: Northrup, Michael J <Michael.Northrup@co.ontario.ny.us>
Sent: Wednesday, January 24, 2018 1:05 PM
To: Zoning Inspector
Cc: Development Clerk; 'Karen Blazey'; Tom Schwartz
Subject: RE: Proposed New Home - Onnalinda Drive

Eric,

Thank you for giving me the opportunity to comment on this private drive off of Onnalinda Dr.

Since April of 2009, the Cheshire Vol Fire Dept. utilizes a custom Class A pumper with a 700gal booster tank and a 1500GPM pump. This engine is also equipped with "locking" four wheel drive and has a small 29 foot wheel base to better enable us to access properties that may present challenges to standard fire apparatus. Additionally, I am aware that this section of the hydranted area is fed by a 8" water main, which meets or exceeds our requirements.

As such, my fire safety concerns are no greater than they may be with any other existing property along the lake and upland lake areas.

**Michael J. Northrup, Chief
Cheshire Vol. Fire Dept. Inc.**

From: Zoning Inspector [mailto:zoninginspector@townofcanandaigua.org]
Sent: Tuesday, January 23, 2018 10:14 AM
To: Northrup, Michael J
Cc: Development Clerk; 'Karen Blazey'; Tom Schwartz
Subject: Proposed New Home - Onnalinda Drive

Mike,

Could you please review the attached documents for fire safety and provide any comments, if any? Thank you.

Eric A. Cooper

Zoning Inspector
Town of Canandaigua
ecooper@townofcanandaigua.org
585-394-1120 x2254

"This message may contain confidential, sensitive and/or proprietary information and is intended for the person/entity to whom it was originally addressed. Any use by others is strictly prohibited."