

**From:** [Braun, Jack D \(Jack.Braun@ontariocountyny.gov\)](mailto:Jack.Braun@ontariocountyny.gov)  
**To:** [devclerk@townofcanandaigua.org](mailto:devclerk@townofcanandaigua.org)  
**Subject:** CPN-21-038  
**Date:** Wednesday, May 5, 2021 2:30:45 PM

---

Good afternoon -

My apologies for not getting this to you by yesterday's deadline - I was off Monday & Tuesday.

\* The Sketch Plan does not show any utilities - currently, the closest sanitary sewer is located in the Villas of Canandaigua development.

\* The site is not within current boundaries of a sewer district extension - the creation of one will be one of the conditions for approval.

Further comments will be provided when more detailed plans are provided.

-jack

John D. Braun  
Junior Engineer, CLCSD

Ontario County Department of Public Works  
2962 County Road 48  
Canandaigua, New York 14424  
(585) 396-4049

"This message may contain confidential, sensitive and/or proprietary information and is intended for the person/entity to whom it was originally addressed. Any use by others is strictly prohibited."