

July 20, 2016

Mr. Doug Finch, Director of Development  
Town of Canandaigua  
5440 Routes 5 & 20 West  
Canandaigua, New York 14424

**RE: PFISTER ENERGY – CANANDAIGUA SOLAR ARRAY  
SITE PLAN REVIEW  
TAX MAP NO. 140.14-1-14.211  
CPN NO. 034-16 & 035-16  
MRB PROJECT NO.: 0300.12001.000 PHASE 84**

Dear Mr. Finch,

MRB has completed a review of the submitted Site Plan regarding the above referenced project, dated June 24, 2016, last revised July 19, 2016 prepared by Hunt Engineers, Architects, and Surveyors. We offer the following comments for the Planning Board's consideration. A brief written response to each comment should be provided by the design engineer.

1. Please note that Sheet C4-1 (Erosion Control Notes and Details) was not included in the revision submittal. Our previous comment which requested "The notes on drawing C4.1 shall be revised to as necessary regarding the Town of Canandaigua's status as a MS4, specifically notes I-2, I-3, III-6, VI, and VIII" remain outstanding and need to be addressed.
2. It is our understanding that the wetlands that were identified along the County Road 46 property line is actually a stream. Therefore, the stream should be identified and labeled on all plans. All references to wetlands and the wetland buffer (Existing Conditions and General Notes) should be removed.

If you have any questions, comments or concerns regarding any of the above comments please call me at our office.

Sincerely,



Lance S. Brabant, CPESC  
Senior Planning Associate

N:\0300.12001.000\CORRES\086-City of Canandaigua - Solar Farm\srl-rev2.doc

SOLUTIONS YOU CAN TRUST

The Culver Road Armory - 145 Culver Road, Suite 160, Rochester, NY 14620 - 585-381-9250; FAX 585-381-1008