

Comments on projects for the planning board

Application # CPN-18-013

3365 State route 364

1. Marvin Sands Drive has an 8 inch ACP water main. Spoke to Mark that a back side tap would not be required.
2. When pulling the HDPE back under the road a tracer wire of 10 gauge copper will be placed with it.
3. One water service for the fire and domestic water. An engineered drawing of both back flow devices needs to be submitted to the water superintendent for his review and the Dept. of Health. Spoke to Mark about this and he is working on it.
4. A tracer wire will be placed with the six inch water main and into the building.
5. The materials and labor will be required to be paid prior to the town performing the work. The payment will be to the town of Canandaigua

Application # CPN-18-010

Johnson road new house for Brian Russo

1. Homeowner needs to pay for the tapping of the water service to the property before town will perform the work. Use our town web site under permits to apply for the application.
2. A pressure reducing valve that is maintained and provided by the property owner be placed after the water meter. The water pressure at the road is 140 PSI
3. Will the property owner need a 1.5 inch water service?
4. A 10 gauge solid copper tracer wire will be placed in the trench with the water service pipe.
5. Inspection by the town of the water service has to be performed before backfilling
6. Do not use a union to splice two pieces of water service
7. A permit to install a driveway will need to be completed.
8. The driveway entrance is required to be paved the first 20 feet from the edge of the road.
9. Mailbox it to be installed 15 feet from the center line of the road.

Application # 5497 Rochester Point Drive

Mike Collins and Wende Cleary

1. Maintain the curb stop from being damaged during the work.

5420 County Road 30 Synergy Field

1. Will work with contractor for road improvements.