

From: Havens, Donald E <Donald.Havens@ontariocountyny.gov>
Sent: Tuesday, November 3, 2020 2:23 PM
To: devclerk@townofcanandaigua.org
Subject: November Zoning and Planning comments

Hi Michelle,

The Canandaigua Lake Sewer District has the following comments on the following applications.

- Application# - CPN-20-073 – Addition may impact sanitary lateral that services this address. Full site plan showing sewer lateral required for our review and may require a renovation permit from the District.
- Application# - CPN-20-076 – No Comments at this point.
- Application# - CPN-20-072 – Permit required for connection. Current drawings look in order but changes will require drawings to be resubmitted to this office. Also may require a County Highway ROW work permit.

Thanks,
Don

Don Havens
Canandaigua Lake County Sewer District Supervisor
Ontario County Public Works Department
2962 County Road # 48
Canandaigua, N.Y. 14424-9553
Office (585) 396-4301
Office Hours: M-F 7:00 AM to 3:30 PM

"This message may contain confidential, sensitive and/or proprietary information and is intended for the person/entity to whom it was originally addressed. Any use by others is strictly prohibited."