

Comments for the planning board- Jim Fletcher- 9/14/21

CPN-21-060 4531 Tichner Point

1. The water service is not known where it is on the property. Due to the time, it was installed back in the late 60's we do not have any record drawings.

CPN-21-066 German

1. No comment

CPN-21-056 2536 State route 332

1. Change the signature line to Canandaigua Farmington water.

CPN-21-050 Onnalinda Drive

1. No Comment

CPN-21-073 4799 County Road 16

1. Before home is remove the water meter needs to be remove and the water turned off at the curb stop at the road.
2. Will the property have a basement? If not, the water meter must be in a location that is accessible to town employees.
3. A pressure reduce valve will be required after the water meter.
4. Will the new water service be a one-inch CTS 200? If so a ¾ by 1-inch compression coupling will be needed after the curb stop to connect to it.
5. Will irrigation be installed? If so an engineered plan will have to be submitted to the NYS Dept of Health and the town of Canandaigua for approval.

CPN-21-074 2121 State route 332

1. No comment.

CPN-21-075 4520 County Road 16

1. No comment

CPN-21-076 4963 Water Edge

1. Coordinate with the water department for operating curb stop
2. Contact water department to pay for the water meter and time to install.
3. Pressure reducing valve must be after water meter.
4. If an irrigation system is installed a engineered plan must be submitted to the NYS dept of Health and the town of Canandaigua for approval.

CPN-21-077 3060 County Road 10

1. No comment

CPN-21-068