



HYDRANT FLOW TEST DATA
(Supplied by Farmington Water and Sewer Department)
Test Date: July 11, 2018
Residual Hydrant: West Side of Rt. 332
Flow Hydrant: East Side at 2121 Rt. 332
Static Pressure: 71 psi
Residual Pressure: 58 psi
Measured Flow Rate: 1350 gpm

State Route 332

FLX Marine Unenclosed Sales Area Expansion