

## Development Clerk

---

**From:** Eric Cooper <zoninginspector@townofcanandaigua.org>  
**Sent:** Monday, August 19, 2019 12:49 PM  
**To:** mrowlinson@townofcanandaigua.org  
**Subject:** FW: State Route 332 2281

---

**From:** cjensen@townofcanandaigua.org <cjensen@townofcanandaigua.org>  
**Sent:** Monday, August 19, 2019 12:07 PM  
**To:** ecooper@townofcanandaigua.org  
**Subject:** State Route 332 2281

### Project Review – Comments

- Site disturbance is over 1 acre – applicant to provide SWPPP report and associated NOI for Town review and approval signature – Town is an operator of a MS4
- Prior to permit being issued – SWPPP Contractor agreement/information to be provided
- Prior to permit being issued – SWPPP Engineer/Inspector agreement/information to be provided
- Property owner is incorrectly listed. Should be 'Stella's Florist LLC'
- Note should be added to the plans that the fill is to be 'clean' material. No construction debris.

Chris Jensen PE MCP  
Code Enforcement / Zoning Officer  
[Town of Canandaigua](#)  
5440 Routes 5 & 20 West  
Canandaigua, NY 14424  
Cell (585) 315-3088