



CITY OF CANANDAIGUA FIRE DEPARTMENT

Fire Chief Frank Magnera
335 South Main Street
Canandaigua, NY 14424-2118
Phone (585) 396-5052 Fax (585) 394-2706



Plan Review Comments

Application: **CPN-21-056**

BME for Cdga. Crossings, LLC
2536 State Route 332, Canandaigua, NY 14424

July 01, 2021

To whom this may concern:

The Fire Department has reviewed the proposed Site Plan for 2536 State Route 332.

- Please ensure fire department sprinkler connection (FDC) is a 4" Storz with 30 degree down angle.
- Please install a Knox Box per Fire Department's recommendations.

No further concerns or comments at this time.

If you have any questions feel free to contact me. Thank you.

Respectfully,

Frank A. Magnera

Frank Magnera, MS, CFPS
Fire Chief & Fire Marshal