

Ontario County Public Works

William C. Wright, P.E. Commissioner of Public Works Office: (585) 396-4000 2962 County Road 48
Canandaigua, New York 14424-9553
www.co.ontario.ny.us
email: dpw@co.ontario.ny.us

Timothy G. McElligott, P.E. Deputy Commissioner of Public Works Facsimile: (585) 396-4283

HIGHWAYS ~ ENGINEERING ~ WASTEWATER SYSTEMS & SEWERS ~ BUILDINGS & GROUNDS ~ PARKS ~ PUBLIC WORKS FINANCE

August 5th, 2021

James G. Cretekos, P.E. BME Associates 10 Lift Bridge Lane East Fairport. New York 14450

Re: 2536 Rochester Road Apogee Development LTD. Canandaigua, New York 14424

Dear Mr. Cretekos:

We are in receipt of a site plan set for the referenced project dated July 27th, 2021.

GENERAL

1. Permit required for the proposed new structure.

SITE PLAN

- 1. Add "Standard Sanitary Lateral Plan Notes".
- 2. Add "Inserta-tee" Detail.
- 3. Re-Label "6" PVC" to "6" SDR-21" on lateral comment next to proposed structure.
- 4. Re-Label sewer main "18 VCP to 18 ACP" from sewer main.
- 5. Clean outs are required up stream of every change of direction and every 90 feet.
- 6. Label man hole to the North West 148, man hole to the South East 148A and the man hole in the right of way of NYS Route 332 149.
- 7. Any disturbance of asbestos concrete piping requires a licensed abatement contractor for handling and disposal including the new 6 inch tap for the "Inserta-tee" connection.
- 8. Be aware that there is a 4 inch AC lateral on this property that serviced the property in the past. If any damage should occur to this lateral it will be required to be repaired and inspected by district personnel before burial.

Please make revisions and resubmit to our office. If you have any questions I may be reached at (585) 396-4301

Sincerel

Donald E. Havens,

Supervisor, Canandaigua Lake Sewer District

Enc.

cc: Steven P. May, Supervisor, Bureau of Wastewater Management (w/o enc.)
Chris Jensen, P.E., Code Enforcement/Zoning officer, Town of Canandaigua (w/o enc.)