

From: [James Cretekos \(jcretekos@bmepc.com\)](mailto:jcretekos@bmepc.com)
To: [Sowinski, Collin](#)
Cc: lance.brabant@mrbgroupp.com; [Peter Vars](#); [Bill Dowell](#); [Shawna Bonshak](#); [Oyler, Charles](#); mrowlinson@townofcanandaigua.org
Subject: 2759 Rochester Road - MRB Stormwater Comments
Date: Tuesday, August 24, 2021 2:35:12 PM
Attachments: [image001.png](#)
[2759-07 Grading Plan.pdf](#)
[2759 Phase II CPv Orifice Spillway Calculations 2021-08-24.pdf](#)

Hi Collin,

Thanks for reaching out this morning with your couple questions on the Rochester Road proejct. Here are responses to the 3 items we discussed.

1. Dry Swale grading clarification – we updated the linetypes/thickness on the plans to make it more readable and will be reflected on all future sets & mylars. Grading Plan attached for reference.
2. CPv Calc – Corrected the Direction Runoff Q value and added the contour areas to the table as requested. We did reduce the CPv required per the RRV provided, which still shows we are in compliance with the NYSDEC requirements for CPv.
3. CDS Unit - We will review the proprietary stormwater practices to see if any can be utilized in the place of the CDS unit proposed and coordinate with MRB.

Let us know if you have any other questions prior to the Planning Board meeting tonight. Thank you,

James G. Cretekos, P.E.
Project Manager / CAD Manager



10 Lift Bridge Lane East
Fairport, NY 14450
Phone: (585) 377-7360 x102
Fax: (585) 377-7309
www.bmepc.com
jcretekos@bmepc.com