

## Development Clerk

---

**From:** Trost, Gregory J (DOT) <Gregory.Trost@dot.ny.gov>  
**Sent:** Wednesday, July 10, 2019 11:22 AM  
**To:** devclerk@townofcanandaigua.org  
**Subject:** CPN-19-051

Greetings,

Thank you for sending the plan on the above referenced project for review. This project has been sent to the regional office for review. A preliminary review found that the NYSDOT should be ok with extending the two way left turn lane to allow lefts into the site. We'll determine the proper length and layout later on in the permitting process. The left turn lane exiting is acceptable as well. The driveway should have three 12' lanes. We also just need to emphasize that if there are ever any accident issues with this driveway we would look into restricting lefts in and/or out at that time.

Also, any utilities needed would require a permit to be obtained by the utility company(ies).

Thank you for allowing me to comment.

Sincerely,  
Greg

**Greg Trost**

Assistant Resident Engineer

**New York State Department of Transportation**

125 Parrish Street, Canandaigua, NY 14424

(585) 396-4957 | [gregory.trost@dot.ny.gov](mailto:gregory.trost@dot.ny.gov)

[www.dot.ny.gov](http://www.dot.ny.gov)



**Department of  
Transportation**