



Ontario County Public Works

William C. Wright, P.E.
Commissioner of
Public Works
Office: (585) 396-4000

2962 County Road 48
Canandaigua, New York 14424-9553
www.co.ontario.ny.us
email: dpw@co.ontario.ny.us

Timothy G. McElligott, P.E.
Deputy Commissioner
of Public Works
Facsimile: (585) 396-4283

HIGHWAYS ~ ENGINEERING ~ WASTEWATER SYSTEMS & SEWERS ~ BUILDINGS & GROUNDS ~ PARKS ~ PUBLIC WORKS FINANCE

September 13th, 2022

Brett L. Steenburgh, P.E. PLLC
2832 Rosendale Road
Niskayuna, New York 12309

Re: Liberty Restaurants
3225 State Route 364
Canandaigua, New York 14424

Dear Mr. Steenburgh:

We are in receipt of a site plan set for the referenced project dated December 20th, 2021 and received in our office on August 29th, 2022.

GENERAL

1. Renovation permit required for connection.

SITE PLAN

1. Add "Standard Sanitary Lateral Plan Notes" and remove current notes on plan.
2. Add District clean out detail.
3. Add District trench and bedding detail and remove sanitary sewer reference from current trenching and bedding detail.
4. Provide make and model of grease interceptor.
5. Provide sizing calculations for grease interceptor.
6. If reusing current lateral the district requires that the lateral be televised to see that it is viable for reuse.
7. If current lateral is SDR-35 and is acceptable for reuse the same material can be reused if not it must be upgraded to district standards of SDR-21.

Please make revisions and resubmit to our office and after approval we will issue a lateral permit. If you have any questions I may be reached at (585) 396-4301

Sincerely,

A handwritten signature in blue ink, appearing to read "Donald E. Havens, Jr.", written over a faint circular stamp.

Donald E. Havens, Jr.
Supervisor, Canandaigua Lake Sewer District

Enc.

cc: Steven P. May, Supervisor, Bureau of Waste Water Management. (w/o enc.)
Chris Jensen, P.E., Code Enforcement/Zoning Officer, Town of Canandaigua (w/o enc.)