

## Development Clerk

---

**From:** Trost, Gregory J (DOT) <Gregory.Trost@dot.ny.gov>  
**Sent:** Thursday, July 05, 2018 11:57 AM  
**To:** 'devclerk@townofcanandaigua.org'  
**Subject:** CPN-18-042

Greetings,

Thank you for sending me the plans for the work to occur on Route 364. This being the site of the old Lincoln Hill Inn, I looked at our record plans from when the State did a highway job in 1994. At that time, we actually paved their driveway, though left it substandard on width, for reasons unknown. The standard now for a commercial driveway is 24' wide in a one lane in, one lane out configuration. They are proposing a 24' wide throat width driveway, which is acceptable to the NYSDOT. Seeing that there was a commercial establishment there previously, and is proposed to be a commercial establishment, we concur with what they are proposing for a driveway width. Radii size does seem too small though. A highway work permit, PERM 33, type 5b2c, would be required to widen that driveway and subsequent gutter work, as the standard for gutter has it flare out at a driveway, the entire width. A permit like that would be approved in my office and if the owner has any questions, I can be reached at the address and phone number below.

Thank you,  
Greg Trost

### **Greg Trost**

Assistant Resident Engineer

**New York State Department of Transportation**

125 Parrish Street, Canandaigua, NY 14424

(585) 396-4957 | [gregory.trost@dot.ny.gov](mailto:gregory.trost@dot.ny.gov)

[www.dot.ny.gov](http://www.dot.ny.gov)



**Department of  
Transportation**